

General Environmental Incident Summary

Incident: 3778 **Date/Time Notice:** 6/12/2015 06:20A **DEM Incident No:**
Responsible Party: Flint Hills Resources
Date Incident: 6/12/2015 **Time Incident:** 05:30AM **Duration:** 11 hours
County: Cass **Twp:** 139 **Rng:** 49 **Sec:** 5 **Qtr:**
Lat: 46.88255 **Long:** -96.90125 **Method:** Interpolation from map
Location Description: Flint Hills Resources Pine Bend, LLC
West Fargo Asphalt Terminal
600 Center Street
West Fargo, ND 58078
Submitted By: Tamara Martin **Affiliation:**
Address: 13775 Clark Road
City: Rosemount **State:** MN **Zip:** 55068

Received By:

Contact Person: Eric Dominiack
600 Center Street
West Fargo, ND 58078

Distance Nearest Occupied Building: 300 Feet **Release Contained:** Yes

Type of Incident: Tank Leak

Description of Released Contaminant: Asphalt Cement

Volume Spilled: 500.00 gallons

Ag Related: No

EPA Extremely Hazardous Substance: No

Reported to NRC: Unknown

Cause of Incident:

Asphalt Tank leaking from base. Suspect small hole in floor of tank.

Risk Evaluation:

NONE

of Fatalities: 0

of Injuries: 0

Affected Medium: 03 - soil

Potential Environmental Impacts:

NONE

Action Taken or Planned:

This spill was previously reported to the NDDH at 6:20AM to Brandy. Spill is on-going and being contained within secondary and tertiary containment inside the facility, as discussed with Pete Wax, NDDH.

Wastes Disposal Location: Asphalt cement and gravel will be disposed through approved landfills.

Agencies Involved:

Updates

Date: 6/12/2015 ***Status:*** Reviewed - Assigned to NDDoH Division

Author: Martin, Russell

Updated Volume:

Notes:

Release, due to tank leak, at a non-E&P exempt facility according to the report. Follow-up is necessary.